

# Interreg - IPA CBC

## Bulgaria - Serbia



Republic of Serbia  
Municipality of Surdulica  
Kralja Petra I no.1  
[www.surdulica.org](http://www.surdulica.org)

16.06.2017

### List of questions and answers


**Program name: Interreg – IPA Cross-border Cooperation Bulgaria Serbia Programme  
2014TC16I5CB007 – 1**

**Project name: „The brass band music of Bulgaria and Serbia in support of cross-border  
festival tourism „**

**Publication Ref: 2014TC16I5CB007-2015-1-CB007.1.11.273 – 2- PP2-WORKS  
(404-56/17-01)**

**Project title: Works tender procedure related Reconstruction works of the building of  
SCC in Surdulica under subsidy contract 2014TC16I5CB007-2015-1-CB007.1.11.273**

QUESTION	ANSWER
Whether the number of zeros denoted by the range of the light beam (130 to 590; 100 to 650; 120 to 610; 50 to 650;) indicates the degree symbol angulation or this number should be treated as a three-digit designation for the size of the degree of angulation given , it is not possible to offer stage reflector the three-digit range beam size.	The zero indicates the degree symbol angulation.
Is it possible to get a clarification on the label lampholder for bulb strength 2.0kW per cent is indicated GX16 for this intensity of light bulbs for the Performing reflectors marking the throat Gy16.	GY16 is right mark of light throat.
Is it possible to offer the same characteristics of the reflector with just gle filters instead of glass filters	It is possible to offer the same characteristics of the reflector with just gle filters instead of glass filters.



**Aleksandra Popovic,**  
**Mayor of Surdulica Municipality**